

Evidence of Performance

Joint sound reduction of filling material

Test Report

No. 18-001310-PR01

(PB 01-K05-04-en-01)



Client **Selena Labs Sp.zo.o**
ul. Pieszycka 4
58-200 Dzierżonów
Poland

Basis

EN ISO 10140-1: 2016
EN ISO 10140-2 : 2010
EN ISO 717-1 : 2013

Representation



Instructions for use

This procedure is suitable for the comparison of construction products designed for sealing (e.g. gaskets/seals, fillers for joints). The results can be used to evaluate the sound power ratio τ_e according to EN 12354-3 Annex B. Using the calculated sound reduction of the joint for the calculation of the overall sound reduction is not a substitute for the sound reduction verification of the overall construction.

Validity

The data and results given relate solely to the tested and described specimen. Testing the sound insulation does not allow any statement to be made on any further characteristics of the construction submitted regarding performance and quality.

Notes on publication

The ift Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

The cover sheet can be used as an abstract.

Contents

The test report contains a total of 11 pages:

- 1 Object
 - 2 Procedure
 - 3 Detailed results
 - 4 Instructions for use
- Data sheet (1 page)

| | |
|------------------|---|
| Product | One component PU-Foam |
| Designation | Ultra Fast Gun PU Foam |
| Density | 11.1 g/l (width of joint 10 mm) 9.5 g/l (width of joint 20 mm) |
| Special features | -/- |

Weighted sound reduction index of joints $R_{s,w}$
Spectrum adaptation terms C and C_{tr}

Test 1 (10 mm width of joint)



$$[R_{s,w} (C; C_{tr}) \geq 63 (-2;-5) \text{ dB}]$$

Test 2 (20 mm width of joint)

$$[R_{s,w} (C; C_{tr}) \geq 63 (-2;-5) \text{ dB}]$$

ift Rosenheim
04.06.2018

Bernd Saß

Bernd Saß, Dipl.-Ing. (FH)
Deputy Head of Testing Department
Building Acoustics

F. Brechle

Florian Brechle, MSc, Dipl.-Ing. (FH)
Operating Testing Officer
Building Acoustics